



DEPARTMENT OF HEALTH LABORATORY

359 SOUTH PARK DRIVE
COLCHESTER, VT 05446
(802) 338-4724 or (800) 660-9997 (VT only)
www.healthvermont.gov

Results Report
State Health Dept # 22-WB-02477
Report Status Final
Date Report Released 07/06/2023

Report To Town of Underhill Rec Dept
ATTN of Brad Holden
Address PO Box 120
Underhill, VT 05489

Account Name Town of Underhill Rec Dept
Date Received 07/05/2023
Time Received 09:47

Sample Desc. KIT SW Sample Type N/A
Collection Date 07/05/2023 Collection Type N/A
Collection Time 08:45 Free Chlorine Residual N/A
Sampled By Emilie Soisson Total Chlorine Residual N/A
Sampling Location Underhill Town Pond Chlorinated? N/A
Street Address Stevensville Rd Field Temp. N/A
Town Underhill State VT Field Fluoride N/A
Temp at Receipt N/A

Test Enzyme Substrate Quantitation 2000 Date/Time of Analysis 07/06/2023 11:40
Test Method SM 9223B-QT

Analyte MPN/100mL
E.coli 14

The water sample tested was found to contain LESS than 235 E. coli per 100mL. This water is considered SUITABLE FOR SWIMMING. This test does not indicate if the water sample is suitable for drinking. Drinking raw water such as an untreated lake, pond or stream is not advised. **NOTE: It is recommended that testing of recreational water begin within 6 to 24 hours of collection for optimal results but testing must begin within 30 hours of collection.

Units of Measurement and Definitions:

N/A = Not Available; mL = milliliter; ">" = greater than; "<" = less than; MPN = Most Probable Number; CFU = Colony Forming Unit; TNTC = Too Numerous To Count
These results are for a grab sample; collected at one location and at one point in time unless otherwise noted.

Test results relate only to the samples tested and are representative of the samples as they were received at the laboratory.

This is a public record. Information contained in this report may be used for statistical purposes and may be released upon request, pursuant to Vermont Access to Public Documents law (1 V.S.A. 315-320). For guidance and treatment recommendations, please visit www.healthvermont.gov/water-contaminants.

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Test Report Authorized By: Cheryl Achilles
Laboratory Program Chief - Microbiology

If you have received this document in error or if you have questions about this report, please call 802-338-4724

Please tell us about your experience with the VDH Laboratory by completing the customer survey at https://www.healthvermont.gov/lab